



TOWN OF VERNON

14 PARK PLACE, VERNON, CONNECTICUT 06066

OFFICE OF PERMANENT MUNICIPAL
BUILDING COMMITTEE

Office of the Permanent Municipal Building Committee

APPROVED MINUTES

RECEIVED
VERNON TOWN CLERK
18 JUL -2 PM 2:36

Regular Meeting: May 23, 2018 6:00 P.M. Northeast School

Attendees: George Greco, Joe Greco, Jason Mistretta, Joe Correia

The meeting was called to order at 6:37 p.m. by George Greco after an inspection of Northeast School.

APPROVAL OF MINUTES:

A motion to approve the Minutes of the regular meeting of April 25, 2018 was made by Joe Correia, seconded by Joe Greco, and unanimously approved.


CITIZENS FORUM: None

APPROVAL - INSPECTION OF TOWN BUILDINGS:

A motion to approve the Inspection Report for the new Senior Center was made by Joe Greco, seconded by Jason Mistretta, and unanimously approved.

ANY OTHER BUSINESS: None

The meeting was adjourned at 6:48 p.m. with a motion made by Joe Correia, seconded by Joe Greco, and unanimously approved.


Julie A. Mathison, Recording Secretary

INSPECTION OF TOWN BUILDINGS

NORTHEAST SCHOOL

PERFORMED BY THE PERMANENT MUNICIPAL BUILDING COMMITTEE

MAY 23, 2018

1. Some tiles are buckling in the entryway of East Main Street.
2. Bolts are missing in various beams in the library and some of the classrooms. *Is this a concern ?*
3. The hot water heater is leaking in the Boiler Room.
4. The floor drain is plugged-up in the Boiler Room.
5. Some sprinkler piping still needs fire caulking where there are openings.
6. Some sprinkler head escutcheons are still missing and should be replaced.
7. The overall cleanliness of the school is very good.

Revised/Approved at 6/27/18 Meeting.

RECEIVED
VERNON TOWN CLERK
18 JUL -2 PM 2:36